

# LONGS PEAK WATER DISTRICT

## DISTRICT SPECIFICATION DETAIL DRAWING

NOTE  
LPWD TO SUPPLY METER.  
ALL OTHER COMPONENTS  
TO BE SUPPLIED BY  
DEVELOPER/CONTRACTOR.  
ALL COMPONENTS TO BE  
INSTALLED BY DEVELOPER/  
CONTRACTOR.

DUAL CHECK VALVE

SERVICE VALVE

1" METER

METER PIT

CASTINGS INC. 16" TRAFFIC  
RATED LID WITH 1 7/8"  
DRILLED HOLE  
MODEL # CI-70-16

TOP VIEW

5'

GROUND LEVEL

FROST PROOF  
LID

SERVICE VALVE

12"

PROPERTY LINE

DUAL CHECK VALVE

METER

1" COPPER YOKE  
(FORD MODEL #  
VBHH94-30W-MM44-J)

DFW PLASTICS INC.  
20"X24"X36"  
HW WHITE  
METER PIT

TRACER  
WIRE

30"

36"

BRASS SADDLE  
AND CORP. STOP

CTS POLY SERVICE LINE  
SEE DISTRICT FOR  
CURRENT SPECIFICATION

18"

1" MALE  
I.P. THREAD

WATER MAIN

1" RESIDENTIAL METER PIT OR  
FIRE SERVICE METER PIT